



# ACT CONCRETE WATER TANKS

## SITE PREPARATION & TANK INFORMATION

### AREA REQUIRED FOR TANK CONSTRUCTION:

**TANK SIZE:**                      **DIAMETER:**  
*TRANSPORTABLE & UNDERGROUND ONLY*

10,000L

3.5M

#### *POURED ON SITE*

20,000L

5.5 M

22,500L

5.5 M

90,000L

10 M

120,000L

11 M

\*THE SITE MUST BE ON NATURAL GROUND (**NO FILL**)

\*THE SITE MUST BE FLAT AND LEVEL

\*REASONABLE ACCESS IS REQUIRED FOR HEAVY VEHICLES

\*BASE MATERIAL TO BE SPREAD OUT AND LEVELLED TO A 50MM DEPTH

\*BASE MATERIAL TO BE 20MM AGGREGATE

**\*SATISFACTORY SITE PREPARATION ELIMINATES COSTLY AND ANNOYING DELAYS**

### TANK DIMENSIONS

VOLUME:	HEIGHT:	DIAMETER:
10,000L	2.6 M	2.5 M
20,000L	2.4 M	3.4 M
22,500L	2.6 M	3.4 M
90,000L	2.4 M	7.5 M
120,000L	2.4 M	8.5 M

### TANKS COME WITH:

\*CONCRETE ROOFS RATED AT 3kPa (unless otherwise advised)

\*LOCKABLE MANHOLE

\*100MM PVC INLETS AND OVER FLOWS

\*50MM BRASS FITTING FOR ABOVE GROUND TANKS

\*25 YEAR GUARANTEE

**THE TANKS ARE NOT DESIGNED FOR BUOYANCY  
DRAINAGE DONE BY OTHERS**